

## Sounding cone resistance data table

Document :			
Site : thames water			
Sounding : TEST2			
Tarmac : 0.00 mm	Pre-sounding depth : 0 mm	Area : 2 cm <sup>2</sup>	Water table : Indefinite
Weight : Panda 2 hammer	Breaking cond. : Temporary	Date : 27/09/2007	Hour : 14:14:00
Operator : S Robinson		Company : Thames Water	
Comments :			
Compaction meets specification requirements			

Index Measure	Depth (mm)	Resist. (MPa)
1	11	12.47
2	19	12.63
3	29	16.43
4	33	45.16
5	37	46.09
6	42	35.21
7	46	51.77
8	50	52.85
9	55	34.82
10	58	46.14
11	61	64.23
12	65	53.29
13	69	40.35
14	75	34.30
15	80	32.81
16	84	38.02
17	92	23.98
18	96	34.51
19	100	40.43
20	105	43.18
21	110	38.29
22	117	27.45
23	119	76.71
24	123	58.81
25	127	60.94
26	129	77.45
27	131	79.70