

## Sounding cone resistance data table

Document :			
Site : thames water			
Sounding : TEST3			
Tarmac : 0.00 mm	Pre-sounding depth : 0 mm	Area : 2 cm <sup>2</sup>	Water table : Indefinite
Weight : Panda 2 hammer	Breaking cond. : Temporary	Date : 27/09/2007	Hour : 14:23:00
Operator : S Robinson		Company : Thames Water	
Comments :			
Compaction meets specification requirements			

<i>Index Measure</i>	<i>Depth (mm)</i>	<i>Resist. (MPa)</i>
1	26	6.48
2	38	9.88
3	50	15.34
4	58	26.47
5	70	13.75
6	81	20.37
7	89	22.61
8	96	27.24
9	106	21.73
10	112	31.51
11	120	24.52
12	127	25.04
13	135	27.19
14	142	27.73
15	153	15.23
16	161	22.10
17	167	20.76
18	174	24.31
19	181	21.51
20	188	20.53
21	196	18.24
22	204	16.11
23	214	16.18
24	222	17.85
25	229	19.83
26	236	20.81
27	243	19.96
28	251	19.54